



Food Safety Department
Regional Analytical Laboratory, Ernakulam,
Dated. 03.07.2020

No. 11085/2020-21


Description of sample : KWA water
Sample details : The sample received in plastic bottle .
Source : Sree Narayana Public School, Poothotta, Ernakulam – 682 307.
Date of Receipt : 23.06.2020
Date of Analysis : Started on 24.06.2020 and completed 30.06.2020
Sample quantity : 2L
Physical Appearance : Clear, colourless, Agreeable odour.

Analytical results :

Sl. No.	Quantity Characteristics	Name of method of test used	Result	Desirable limit prescribed standard as per IS NO. 10500:1991, 2012 IS 3025 WHO 1993
(1)	(2)	(3)	(4)	(5)
1	pH	IS 3025 Part - II	7.02	6.5 to 8.5
2	Turbidity	IS 3025 Part-10	0.02 NTU	Not more than 5 NTU
3	Alkalinity	IS 3025 Part -23	38.0 mg/l	200.0 mg/l
4	Total Hardness (as CaCO ₃)	APHA 23 rd edn	76.0 mg/l	200.0 mg/l
5	Sulphates (as SO ₄ ²⁻)	IS 3025 P 24	35.0 mg/l	200.0 mg/l
6	Iron (as Fe)	Qualitative inorganic Analysis by Vogel	Below Detectable Limit	0.3 mg/l
7	Residual Free Chlorine	IS 3025 Part -26	Nil	0.2 mg/l
8	Fluoride (as F ⁻)	IS 3025 Part -60	Nil	1.0 mg/l
9	Chloride (as Cl ⁻)	IS 3025 Part -32	18.0 mg/l	250.0 mg/l
10	Nitrite	IS 3025 Part -34	0.016 mg/l	0.02 mg/l
11	Ammonia	IS: 3025 Part-34	Nil	0.5 mg/l
12	Nitrate (as NO ₃ ⁻)	APHA Method	8.85 mg/l	45.0 mg/l
13	Total Dissolved solids	Instrumental by conductivity meter	154.0 mg/l	500.0 mg/l

Lower detection limit of Iron 0.1 mg/l

Remarks : കെമിക്കൽ ക്വാളിറ്റി തൃപ്തികരം




Rauls
FOOD ANALYST

The test report relates to the test items only. No enquires will be entertained after one month issuing test report. Reproduction of test report in part of full without permission is prohibited.

PRINCIPAL
SREE NARAYANA PUBLIC SCHOOL
POOTHOTTA

MANAGER
SREE NARAYANA PUBLIC SCHOOL
POOTHOTTA



No. 81/2021

SANITATION CERTIFICATE

COMMUNITY HEALTH CENTRE KEECHERY

PHC UDAYAMPEROOR - UDAYAMPEROOR GRAMAPANCHAYATH

This is to certify that the premises of Sree Narayana Public School, Poothotta
Ward & Door No. (IX-369 Udayamperoor Gramapanchayath) owned by / run by

Managers, S.N.D.P. Yegam Branch No. 1103 Poothotta
has been found fit for running Educational Institute (Sree Narayana
Public School, Poothotta

as per the provisions of the TRAVANCORE - COCHIN PUBLIC HEALTH ACT -1955 The water supply,
utensils, provisions disposal of liquid and solid wastes satisfactory on my inspection.

(Dated 8-3-2021)

This certificate is issuing on the basis of written request from E.N. Muniyappan
Eelampackalby
Pummalke veli, Udayamperoor

This certificate is issuing only for getting D&O Trade license from Udayamperoor Gramapanchayath
Renewing license for the year 20 21 - 2022

Udayamperoor

Date: 9-3-2021


PRINCIPAL
SREE NARAYANA PUBLIC SCHOOL
POOTHOTTA




MANAGER
SREE NARAYANA PUBLIC SCHOOL
POOTHOTTA

HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
UDAYAMPEROOR

